

Meter size based on AWWA C700			
Meter Size	Meter Cody	Thread	Valve Inlet Size
5/8"	1	3/4" NPSM	1
5/8" x 3/4"	2	1" MPSPM	3
3/4"	3	1" NPSM	3
1"	4	1 1/4" NPSM	4

Contact factory for repair parts

Example Part: for 5/8" x 3/4" meter Order 501NL-T3F3				
Series Number	Inlet Connection	Inlet Size	Outlet Connection	Outlet Size
501NL-	T = Swivel Meter Nut	1 = 5/8"	F = Female Iron Pipe	3 = 3/4"
	SR = Iron Yoke Star Nut	3 = 3/4"		4 = 1"
		4 = 1"		

Not all sizes or combinations are available - Contact Factory

(Installation and test procedures on opposite side)

1. Use only for residential and mobile home supply service or individual outlets.
2. The device can be installed in any position.
3. The device shall be installed in an accessible location to facilitate the removal for servicing and testing.
4. Service lines should be thoroughly flushed before installing the device. Excessive pipe sealant or Teflon tape may foul checks. A suitable strainer should be installed upstream of the device.
5. DO NOT use Vaseline®, plumber's grease, or any other petroleum based product on seals or O-rings.
6. Insure that device is installed in proper flow direction. Refer to flow direction arrow on body.
7. Do not over-tighten O-ring cap seal or across body cylinder to avoid distortion.
8. Any sweat fittings must be completed before installing device.
9. A pressure relief valve or expansion tank is recommended downstream of device if thermal expansion conditions are possible.
10. Use only on cold water services. Protect from freezing.
11. Refer to pressure and temperature ratings on device tag.

FIELD INSPECTION AND TEST PROCEDURE

A. DIS-ASSEMBLY

1. Remove the device cap.
2. Remove the dual check assembly using care not to damage device components.
3. Visually inspect seals, sealing surfaces, etc. for debris or damage.

B. TESTING


1. Insert front check into A.Y. McDONALD angle test kit as shown in drawing.
2. Add water to test kit level to upper red line - 42 inches (1.5 psig).
3. Observe water level for up to 5 minutes until water level stabilizes. Water level should not fall below lower red line - 28 inches (1.0 psig).
4. If water column falls below 28 inches the check assembly should be cleaned and re-tested or replaced.
5. Repeat steps B1 - B4 for rear check.

C. RE-ASSEMBLY

1. Clean and inspect device components.
2. Insert check assembly into body correctly corresponding to flow direction on the device body.
3. Re-assemble device cap. Do not over-tighten.

Contact factory for test kit

WARNING: It is unlawful in CALIFORNIA & VERMONT (effective 1/1/2010); MARYLAND (effective 1/1/2012); LOUISIANA (effective 1/1/2013) and the UNITED STATES OF AMERICA (effective 1/4/2014) to use any product in the installation or repair of any public water system or any plumbing in a facility or system that provides water for human consumption if the wetted surface area of the product has a weighted average lead content greater than 0.25%. This prohibition does not extend to service saddles used in California, Louisiana or under USA Public Law 111-380. **WARNING:** This product can expose you to chemicals including lead, which is known to the State of CALIFORNIA to cause cancer and birth defects or other reproductive harm. For more information go to: www.P65Warnings.ca.gov.



Meter size based on AWWA C700			
Meter Size	Meter Cody	Thread	Valve Inlet Size
5/8"	1	3/4" NPSM	1
5/8" x 3/4"	2	1" MPSPM	3
3/4"	3	1" NPSM	3
1"	4	1 1/4" NPSM	4

Contact factory for repair parts

Example Part: for 5/8" x 3/4" meter Order 501NL-T3F3				
Series Number	Inlet Connection	Inlet Size	Outlet Connection	Outlet Size
501NL-	T = Swivel Meter Nut	1 = 5/8"	F = Female Iron Pipe	3 = 3/4"
	SR = Iron Yoke Star Nut	3 = 3/4"		4 = 1"
		4 = 1"		

Not all sizes or combinations are available - Contact Factory

(Installation and test procedures on opposite side)

1. Use only for residential and mobile home supply service or individual outlets.
2. The device can be installed in any position.
3. The device shall be installed in an accessible location to facilitate the removal for servicing and testing.
4. Service lines should be thoroughly flushed before installing the device. Excessive pipe sealant or Teflon tape may foul checks. A suitable strainer should be installed upstream of the device.
5. DO NOT use Vaseline®, plumber's grease, or any other petroleum based product on seals or O-rings.
6. Insure that device is installed in proper flow direction. Refer to flow direction arrow on body.
7. Do not over-tighten O-ring cap seal or across body cylinder to avoid distortion.
8. Any sweat fittings must be completed before installing device.
9. A pressure relief valve or expansion tank is recommended downstream of device if thermal expansion conditions are possible.
10. Use only on cold water services. Protect from freezing.
11. Refer to pressure and temperature ratings on device tag.

FIELD INSPECTION AND TEST PROCEDURE

A. DIS-ASSEMBLY

1. Remove the device cap.
2. Remove the dual check assembly using care not to damage device components.
3. Visually inspect seals, sealing surfaces, etc. for debris or damage.

B. TESTING

1. Insert front check into A.Y. McDONALD angle test kit as shown in drawing.
2. Add water to test kit level to upper red line - 42 inches (1.5 psig).
3. Observe water level for up to 5 minutes until water level stabilizes. Water level should not fall below lower red line - 28 inches (1.0 psig).
4. If water column falls below 28 inches the check assembly should be cleaned and re-tested or replaced.
5. Repeat steps B1 - B4 for rear check.

C. RE-ASSEMBLY

1. Clean and inspect device components.
2. Insert check assembly into body correctly corresponding to flow direction on the device body.
3. Re-assemble device cap. Do not over-tighten.

Contact factory for test kit

WARNING: It is unlawful in CALIFORNIA & VERMONT (effective 1/1/2010); MARYLAND (effective 1/1/2012); LOUISIANA (effective 1/1/2013) and the UNITED STATES OF AMERICA (effective 1/4/2014) to use any product in the installation or repair of any public water system or any plumbing in a facility or system that provides water for human consumption if the wetted surface area of the product has a weighted average lead content greater than 0.25%. This prohibition does not extend to service saddles used in California, Louisiana or under USA Public Law 111-380. **WARNING:** This product can expose you to chemicals including lead, which is known to the State of CALIFORNIA to cause cancer and birth defects or other reproductive harm. For more information go to: www.P65Warnings.ca.gov.