
Cambridge Brass P.D. Box 249 140 Orion Place Cambridge, Ontario Canada N1R 5V1 Tel: (519) 621-5520 Fax: (519) 621-8674 http://www.cambridgebrass.com






MODEL NO. 202NL

PVC x F.I.P.

CURB STOP - BALL STYLE

## FOR POLYETHYLENE PIPE



## PARTS AND MATERIAL:

- 1. VALVE BODY: CAST BRASS, ALLOY C89833
  2. CAP: CAST BRASS, ALLOY C83600
  3. CAP SCREW: STAINLESS STEEL, TYPE 304
  4. STEM: STAINLESS STEEL, TYPE 303
  5. O—RING: NITRILE RUBBER

- 6. ENDBODY: CAST BRASS, ALLOY C89833

- 7. SEATS: TEFLON
  8. BALL: CAST BRASS, ALLOY C89833.
  9. PEP NUT: CAST BRASS, ALLOY C83600
  10. COMPRESSION SEAL: NITRILE RUBBER
  11. SCREW: STAINLESS STEEL, ALLOY 304
- 12. ANTI-FRICTION WASHER: HDPE

## FEATURES:

- ALL COMPONENTS CONFORM TO AWWA STANDARD C800-05
  (ASTM B-584 UNS NO C89833 FOR ALL BRASS PARTS IN CONTACT WITH POTABLE WATER,
  AND ASTM B-62 AND ASTM B-584 UNS NO C83600 FOR ALL OTHER BRASS PARTS).

   CONFORMS TO ANSI/NSF 372 (COMPLIANT WITH US Safe Drinking Water Act. PL 111-380)

   CONFORMS TO ANSI/NSF STANDARD 61-8.

   FLOW CAN BE IN EITHER DIRECTION.

- FLOW CAN BE IN EITHER DIRECTION.
   ROTATION STOPS RESISTS 200 FT-LB TORQUE.
   ENCAPSULATED LUGS UNDER CAP PROVIDE 90 DEGREE OPEN TO CLOSE OPERATION.
   HOLE FOR ATTACHING CURB BOX ROD OR HANDLE IS PROVIDED IN CAP.
   BLOWOUT PROOF DESIGN.
   300 PSI WORKING PRESSURE.

## ORDERING INFORMATION:

FULL 360 ROTATION = ADD "R" TO END OF CATALOG NO. HANDLE = ADD "H" TO END OF CATALOG NO.

Cambridge Brass considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice.

VALVE SIZE	CATALOG NO.	PVC	F.I.P	LENGTH	HEIGHT	APPROX. WT. LBS.	CLASSIFIED NSF 61-8
3/4"	202NL-PJ3F3	3/4"	3/4"	3.47"	2.39"		
1"	202NL-PJ4F4	1"	1"	4.03"	2.60"		
1 1/4"	202NL-PJ5F5	1 1/4"	1 1/4"	4.40"	2.85"		
1 1/2"	202NL-PJ6F6	1 1/2"	1 1/2"	5.52"	3.18"		
2"	202NL-PJ7F7	2"	2"	5.86	3.60"		

Submitted by:

FILE: SUBMITTAL/202-PJ\_F\_DWG REV. A - JSP. JUNE 2012