
Cambridge Brass P.D. Box 249 140 Orion Place Cambridge, Ontario Canada N1R 5V1 Tel: (519) 621-5520 Fax: (519) 621-8674 http://www.cambridgebrass.com






MODEL NO. 203NL

CAMPAK x CAMPAK

CURB STOP - BALL STYLE **DRAINING**

FOR COPPER OR PLASTIC TUBING (CTS)



PARTS AND MATERIAL:

- PARTS AND MATERIAL:

 1. VALVE BODY: CAST BRASS, ALLOY C89833
 2. CAP: CAST BRASS, ALLOY C83600
 3. CAP SCREW: STAINLESS STEEL, TYPE 304
 4. STEM: STAINLESS STEEL, TYPE 303
 5. O-RING: NITRILE RUBBER
 6. ENDBODY: CAST BRASS, ALLOY C89833
 7. SEATS: TEFLON
 8. BALL: CAST BRASS, ALLOY C89833
 9. TAILNUT: CAST BRASS, ALLOY C83600
 10. COMPRESSION SEAL: NITRILE RUBBER
 11. SCREW: STAINLESS STEEL, ALLOY 304
 12. DRAIN SEAL: NITRILE RUBBER
 13. DRAIN PLUG: COPPER, ALLOY C36000

FEATURES:

- CONFORMS TO AWWA C800 (ASTM B584 UNS C89833 FOR ALL BRASS PARTS IN CONTACT WITH POTABLE WATER) AND ASTM B62 AND B-584 UNS NO C83600 FOR ALL DHARS PARTS IN CONTACT AND ASTM B652 AND B-584 UNS NO C83600 FOR ALL OTHER BRASS PARTS).

 CONFORMS TO ANSI/NSF 61-8

 CONFORMS TO ANSI/NSF 372 (COMPLIANT WITH US Safe Drinking Water Act. PL 111-380)

 ROTATION STOPS RESISTS 200 FT-LB TORQUE.

 BLOWOUT PROOF DESIGN.

- BLUWUUI PROUF DESIGN.
 ENCAPSULATED LUGS UNDER CAP PROVIDE 90 DEGREE OPEN TO CLOSE OPERATION.
 VALVES ARE DIRECTIONAL (FLOW DIRECTION ARROWS PROVIDED ON BODY).
 HOLE FOR ATTACHING CURB BOX ROD OR HANDLE IS PROVIDED IN CAP.
 300 PSI WORKING PRESSURE.

ORDERING INFORMATION: FULL 360 ROTATION = ADD "R" TO END OF CATALOG NO. HANDLE = ADD "H" TO END OF CATALOG NO.

Cambridge Brass considers the information in this submittal form to be correct at the time of publication. Item and option availability, including specifications, are subject to change without notice.

VALVE SIZE	CATALOG NO.	INLET CAMPAK	OUTLET CAMPAK	LENGTH	HEIGHT	APPROX. WT. LBS.
3/4"	203NL-B3B3	3/4"	3/4"	3.75"	2.50"	3.8
1"	203NL-B4B4	1"	1"	4.42"	2.68"	6.8
1 1/2"	203NL-B6B6	1 1/2"	1 1/2"	6.56"	3.31"	12.0
2"	203NL-B7B7	2"	2"	6.83"	3.61"	17.0

Submitted by:

FILE: SUBMITTAL/203NL-BB.DWG MD, APRIL 2014